



CONCRETE: 4500 PSI @ 28 DAYS
REINFORCED WITH #4 BARS

RADIO READ UNIT (MXU) TO BE INSTALLED
ON SERVICE LINES AS INDICATED BY
METRO WATER SERVICES PERMIT OFFICE.
REFERENCE DETAIL WDET015A OR WDET015C
FOR LARGE METER FRAME & COVER RADIO
READ UNIT (MXU) MOUNTING LOCATION.

MXU TO BE INSTALLED AS PER
MANUFACTURES SPECIFICATIONS.

METRO WATER SERVICES

METER BOX FOR 4" METER

NOT TO SCALE | DATE: 02/22/08

DWG. NO. WDET002E

METRO
WATER SERVICES

Hal Baltheop
LICENSED DISTRIBUTION OPERATOR

S. J. White
DIRECTOR OF WATER AND SEWERAGE SERVICES