



CONCRETE: 4500 PSI @ 28 DAYS

RADIO READ UNIT TO BE INSTALLED AS PER MANUFACTURES SPECIFICATIONS.

NOTES

SERVICE LINES MUST BE TYPE "K" COPPER WITH FLARED FITTINGS IN METER BOX.

METRO WATER SERVICES

STANDARD 1" METER
AND BOX DETAIL

NOT TO SCALE | DATE: 05/05/08

DWG. NO. WDET018

METRO
WATER SERVICES

Hal Batthys
LICENSED DISTRIBUTION OPERATOR

Sp. Water
DIRECTOR OF WATER AND SEWERAGE SERVICES