



WATER LINE MUST BE PRESSURE CLASS 350 DIP RESTRAINT JOINT, COPPER, OR APPROVED EQUAL.

WATER LINE SHALL BE TESTED AND SAMPLED ACCORDING TO MWS DISINFECTION SPECIFICATIONS.

TAPS TO BE MADE 24 INCHES FROM BELL.

METRO WATER SERVICES

LARGER THAN 1 INCH
DOMESTIC WATER LINE ONLY

NOT TO SCALE | DATE: 4/19/18

DWG. NO. SCHEMATIC 1



Oliver B Scott

LICENSED DISTRIBUTION OPERATOR

[Signature]

DIRECTOR OF WATER AND SEWERAGE SERVICES