



TYPICAL CREEK CROSSING  
FOR SEWER PIPES

NOTES:

- CONCRETE TO BE CLASS "B" AS SPECIFIED IN CONTRACT DOCUMENT SECTION 03300.
- ENCASEMENT WIDTH TO BE POURED THE WIDTH OF TRENCH WITH A MINIMUM OF 4" ON EACH SIDE PIPE.

METRO WATER SERVICES

CREEK CROSSING  
FOR SEWER PIPES

NOT TO SCALE | DATE: 02/22/08

DWG. NO. SDET024

**METRO**  
WATER SERVICES

*Hal Battchop*  
LICENSED COLLECTION OPERATOR

*SM*  
DIRECTOR OF WATER AND SEWERAGE SERVICES