



NOTE: CONCRETE BLOCKING REQUIRED
BEHIND TEE AND BEND SEE
DRAWINGS WDET007 AND WDET009

NOTE : TIE - OVER FOR OTHER SIZES OF
MAINS ARE SIMILAR IN DETAIL, AND
MAY BE MADE BY SUBSTITUTION OF
FITTINGS. EXAMPLE : FOR TIE - OVER
OF 2" MAIN , USE 4" X 2" REDUCER
WITH 2" DIA. NIPPLE AND SLEEVE IN
LIEU OF 2-1/4" FITTINGS.

METRO WATER SERVICES

DETAIL OF TIE - OVER
8" X 2 - 1/4"

NOT TO SCALE DATE: 02/22/08

DWG. NO. WDET019

METRO
WATER SERVICES

Hal Battling
LICENSED DISTRIBUTION OPERATOR

SPitt
DIRECTOR OF WATER AND SEWERAGE SERVICES