



NOTE: REINFORCING TO BE 1/4" STEEL REINFORCING RODS PLACED HORIZONTALLY IN SQUARES TO BE STAGGERED APPROXIMATELY AS SHOWN ON PLAN VIEW, ONE FOR EVERY 3" OF HIGH OF BOX. RODS SHALL BE PLACED IN EACH CORNER OF THE BOX AND AT THE HALF WAY POINT OF EACH SIDE OF THE BOX. USING EIGHT RISERS TO THE BOX.

TOTAL LENGTH OF REINFORCING RODS FOR BOX APPROXIMATELY 47 FEET

CONCRETE MIXTURE TO BE ONE PART CEMENT. TWO PARTS SAND & THREE PARTS NO.2 CRUSHED STONE OR GRAVEL. TOTAL VOLUME OF MIXTURE FOR BOX - APPROXIMATELY 2 CUBIC FEET

METRO WATER SERVICES

STANDARD CONCRETE
VALVE BOX

NOT TO SCALE | DATE: 02/22/08

DWG. NO. WDET012



Fal Balthrop

LICENSED DISTRIBUTION OPERATOR

J. M. Pate

DIRECTOR OF WATER AND SEWERAGE SERVICES